


METRIC

ALL DIMENSIONS SHOWN ARE IN METRES AND/OR MILLIMETRES UNLESS OTHERWISE NOTED.

NOTE:
THIS DRAWING IS PROVIDED FOR INSTRUCTIONAL DESIGN PURPOSES ONLY BASED ON METROLINK GO TRANSIT DESIGN GUIDELINES AND REQUIREMENTS. THE CONSULTANT SHALL VERIFY FOR LOCAL CODE COMPLIANCE, EXISTING SITE CONDITIONS AND INTER DISCIPLINARY DRAWING COORDINATION. ALL DIMENSIONS AND SPECIFICATIONS SHOULD BE VERIFIED BY CONSULTANT AND/OR CONTRACTOR BEFORE ACTUAL CONSTRUCTION BEGINS.

BUILDING AUTOMATION SYSTEM INTERCONNECTION BLOCK DRAWING



GENERAL NOTE:
1. REFER TO ELECTRIFICATION STANDARDS AND SPECIFICATIONS FOR GROUNDING AND BONDING, EMI/EMF WITHSTAND REQUIREMENTS, CABLING REQUIREMENTS.

NOTE:
1. ALL CONDUIT SIZES TO BE 27mmØ UNLESS OTHERWISE NOTED
2. CONSULTANTS ARE TO REVIEW ALL WIRE SIZING TO TAKE INTO ACCOUNT; DERATING AND 3% MAXIMUM VOTAGE DROP FACTORS. WIRE SIZES ARE SUGGESTIONS ONLY!

GO TRANSIT PROJECT NO. XXXXX

AutoCAD drawing: WSP-032.dwg Aug 15/18 12:29pm

REV.	DATE	ISSUED FOR	REV.	DATE	ISSUED FOR
5	FEB. 2018	UPDATES AND ADDITIONS	5	FEB. 2018	UPDATES AND ADDITIONS
4	DEC 2013	DISCLAIMER NOTE	4	DEC 2013	DISCLAIMER NOTE
3	MAR 2013	UPDATES AND ADDITIONS	3	MAR 2013	UPDATES AND ADDITIONS
2	JULY 2012	NOMENCLATURE REVISION	2	JULY 2012	NOMENCLATURE REVISION
1	SEPT.2010	GENERAL REVISIONS	1	SEPT.2010	GENERAL REVISIONS

DRAWN BY:	DESIGNED BY:
CHECKED BY:	APPROVED BY:
SCALE: N.T.S.	FULL SIZE ONLY



XXXXXX WAYSIDE POWER BUILDING AUTOMATION SYSTEM BLOCK DIAGRAM			
CONTRACT NO. XXXXXXXXXX	DWG. NO. WSP-032	REV. 5	SHEET XX