



INSTALLATION NOTES:

- 1 PROVIDE NEW 800A, 600V, 3 POLE SPLITTER IN NEMA 4x CABINET TO ACCEPT CABLE AS INDICATED.
- 2 PROVIDE 3-RUNS OF 3-1/C 750kcmil Cu RWU90 PLUS GROUND IN NEW CONDUITS.

NOTES:

- 1. REFER TO ELECTRIFICATION STANDARDS AND SPECIFICATIONS FOR GROUNDING AND BONDING, EMI/EMF WITHSTAND REQUIREMENTS, CABLING REQUIREMENTS

NOTE:  
THIS DRAWING IS TO BE USED ONLY AS A REFERENCE DRAWING FOR EXISTING INSTALLATIONS AND EXPANSION OF EXISTING EQUIPMENT AS NECESSARY. NOT TO BE USED IN NEW DESIGNS.

NOTE:  
THIS DRAWING IS PROVIDED FOR INSTRUCTIONAL DESIGN PURPOSES ONLY BASED ON METROLINX GO TRANSIT DESIGN GUIDELINES AND REQUIREMENTS. THE CONSULTANT SHALL VERIFY FOR LOCAL CODE COMPLIANCE, EXISTING SITE CONDITIONS AND INTER DISCIPLINARY DRAWING COORDINATION. ALL DIMENSIONS AND SPECIFICATIONS SHOULD BE VERIFIED BY CONSULTANT AND/OR CONTRACTOR BEFORE ACTUAL CONSTRUCTION BEGINS.

GO TRANSIT PROJECT NO. XX

REFERENCE DRAWINGS		ISSUE		REVISIONS		DRAWN BY: XX XX	DESIGNED BY: XX XX		XXXXXX WAYSIDE POWER SINGLE LINE DIAGRAM			
						CHECKED BY: XX XX	APPROVED BY: XX XX					
						SCALE: N.T.S. FULL SIZE ONLY						
DWG NO.	TITLE	REV.	DATE	ISSUED FOR	REV.	DATE			CONTRACT NO. XX	DWG. NO. WSP-101	REV. 0	SHEET XX XX

D SIZE 22" x 34" (558.8mm x 863.6mm) Aug 15, 2018, 12:31pm Login name: oned6969 Drawing Name: C:\Users\oned6969\Desktop\WSP-101.dwg