

ALL DIMENSIONS SHOWN ARE
IN METRES AND/OR MILLIMETRES
UNLESS OTHERWISE NOTED.

1. LIGHTING POLE ASSEMBLY SHALL BE OCTAGONAL HOT DIP GALVANIZED STEEL C.S.A. G40 21.44W MIN. WITH 50ksi YIELD ALL WELDING IN ACCORDANCE WITH CSA W59 & W47.1 DESIGNED TO AASHTO WITH 80mph WIND SPEED & 1.3 GUST FACTOR, DESIGNED FOR EPA OF 10 MINIMUM.
2. LUMINAIRE MATERIAL AND FINISH AS PER SPECIFICATION. COLOR TO BE PLATINUM SILVER. LUMINAIRE MANUFACTURER TO SUPPLY VERTICAL SLIP FITTER MOUNTS.
3. FOR CONCRETE FOUNDATION SEE STANDARD NO. LS-12-002 AND LS-12-003.
4. FOR WIRING DIAGRAM SEE STANDARD NO. LS-12-003.
5. FIBRE TUBING TO BE PEELED OFF 900mm FROM THE TOP AFTER CONCRETE HARDENS.
6. PROVIDE LOADING IN THE DESIGN FOR 1m x 1m STATIC SIGN SEE DRAWING LS 00



REFERENCE DRAWINGS		ISSUE		REVISIONS		DRAWN BY: X.X.X. YY/MM/DD	DESIGNED BY: YY/MM/DD	 A Division of METROLINX	XXXXXXXXX STATION 12 m LIGHT POLE ELEVATION AND DETAIL				
						CHECKED BY: YY/MM/DD	APPROVED BY: YY/MM/DD						
				3									
				2	26/05/14	REVISED NOTE 2							
				1	20/12/13	DISCLAIMER NOTE							
DWG NO.	TITLE	NO.	DATE	ISSUED FOR	REV.	DATE	SCALE: 1:XXX FULL SIZE ONLY			CONTRACT NO. XX-200X-EN-XXX	DWG. NO. LS 12-001	REV. 3	SHEET