



A circular logo with a horizontal line. Above the line is the letter 'A'. Below the line is the text 'LS-06H-001.1'.



B
LS-06H-001.1



NOTE: EQUIPMENT BOX ASSEMBLY SHALL BE FIELD INSPECTED IF NECESSARY FOR APPROVED TO USE



THIS TYPICAL 6m STRAIGHT SQUARE GALVANIZED STEEL POLE ASSEMBLY IS GENERAL GUIDANCE FOR ELECTRICAL INSTALLATION APPLICABLE TO PLATFORM, HINGED POLES ARE USED AT PLATFORM ONLY TO ELIMINATE NEED FOR FLAGGING. FOR POLE AND CONCRETE FOUNDATION DETAIL, REFER TO DRAWING LS-06H-002 TO LS-06H-005.

1. INTENTIONALLY LEFT BLANK
2. THE HORIZONTAL AND VERTICAL TRACK CLEARANCES FOR ALL PLATFORM LIGHTING POLE INSTALLATIONS SHALL COMPLY WITH THE LATEST CANADIAN NATIONAL AND/OR CANADIAN PACIFIC RAILWAYS STANDARD CLEARANCE DIAGRAM. THE DESIGNER TO DETERMINE EXACT DISTANCE AND MUST OBTAIN WRITTEN APPROVALS BEFORE ANY WORK IS STARTED.
3. INTENTIONALLY LEFT BLANK
4. INTENTIONALLY LEFT BLANK
5. INTENTIONALLY LEFT BLANK
6. GROUNDING RODS TO BE LOCATED AT BASE OF EVERY POLE.
7. ORIENT POLES SUCH THAT POLE SWINGS PARALLEL TO TRACK.
8. CCTV POLE CONSTRUCTION AND COMPONENTS SHALL BE HOT DIP GALVANIZED STEEL C.S.A G40.21-4 W MINIMUM WITH 50KSI YIELD.
9. SEE ELECTRICAL SPECIFICATIONS FOR ALL WELDING, WIND SPED AND EPA STANDARDS.
10. ALL FASTENERS TO BE STAINLESS STEEL EXCEPT WHERE NOTED OTHERWISE.
11. POLE MANUFACTURER SHALL SUPPLY BOLTS, NUTS AND WASHERS TO SUIT DESIGN SECIFIED IN NOTE 10 ABOVE.
12. INTENTIONALLY LEFT BLANK.
13. NUTS AND BOLTS TO BE STAINLESS STEEL
14. CCTV CAMERA SHALL HAVE DRIP LOOPS REFER TO DRM AND I&IT STANDARDS FOR FURTHER DETAILS

REFERENCE DRAWINGS		ISSUE			REVISIONS			DRAWN BY:	DESIGNED BY:		XXXXXXX STATION 6m CCTV HINGED POLE STANDARD DETAIL			
							Chris Jukutas	YY/MM/DD						
							CHECKED BY:	APPROVED BY:						
							YY/MM/DD	YY/MM/DD						
							3	24/07/05	RELOCATED DETAIL FROM LS-06H-003. REVISED NOTES					
							2	14/05/26	REVISED NOTE 5					
		01	20/12/13	DISCLAIMER NOTE			1	05/12/19	SIGNAGE AND CCTV POLES MADE SEPARATE					
		00	10/01/12	NAME UPDATE										
DWG NO.	TITLE	NO.	DATE	ISSUED FOR	REV.	DATE	SCALE: 1:XXX FULL SIZE ONLY							

CONTRACT NO. XX-200X-XX-XXX		DWG. NO. LS 06H-001.1		REV. 3	SHEET
--------------------------------	--	--------------------------	--	-----------	-------